

INDIAN INSTITUTE OF TECHNOLOGY KHARAGPUR  
ESTATE (E&M) WORKS SECTION

Dated: 30.10.2017

CORRIGENDUM

CORRIGENDUM to NIT: IIT/E/E&M/T/27/2017-18 dt. 13.09.2017

Sl.No.	Name of Work
1	Electrical works associated with Classroom Nalanda Complex at IIT Kharagpur

The following modification to the specification may be noted

Printed As	To be Read As
“Supplying and fixing of 6M pop up type flush mounting box with enclosure and all accessories. Including necessary connection as required (for dais only) Make: pop up box – Legrand (Cat No. 054012/ Schneider/ Hager Switch. Socket – legrand (Arteor)	“Supplying and fixing of 6M pop up type flush mounting box with enclosure and all accessories. Including necessary connection as required (for dais only) with S&F of 10amp switch and 16A sockets (2sets) for each box. Make: pop up box – Legrand (Cat No. 054012/ Schneider/ Hager Switch. Socket – legrand (Arteor)

Sr. Executive Engineer (EW)